



Quote

Date: May 1, 2024

Per: Barr Inc

Re: used .75 hp medium temp system
+35 degree cooler
1 phase, 208/230 volt power supply

Salesperson: **Jarvis McLimans**

Used .75 hp medium temp system to include "a&b" below:

A)-(1) used .75 hp copeland mnfg indoor condensing unit (mcfh-0078cav)

With model "rst55c1" copelaweld compressor

208/230 volt, 1 phase, r-22 or equal

Rating: 6,520 btuh @ +25 degree sst

B)-(1) used bohn mnfg mod.adt-065asw evaporator

1 fan, 1/115 volt, air defrost, low profile, 825 cfm

Approx dim: 15"w x 30"l x 16"h

Rating: 6,500 btuh @ 10 degree td

Note: system spec'ed for +35 degree cooler, +25 degree sst, +90 degree ambient and operation on r-22 or equal.